



Lehigh Acres - Municipal Services Improvement District

Project:

SOUTHWEST LEHIGH WEIRS PROJECT

**(A.B.S.O.R.B.)
AQUIFER BENEFIT and STORAGE for
ORANGE RIVER BASIN**

Addendum # 4

OWNER:

**Lehigh Acres - Municipal Services Improvement District
601 East County Lane
Lehigh Acres, FL 33936
(239) 368-0044 Phone - (239) 368-5412 Fax**

ENGINEER:

**RHT ENGINEERING, INC.
319 INMAN STREET
LEHIGH ACRES, FLORIDA 33936
T: (239) 369-8900**

The following Southwest Lehigh Weirs Project (A.B.S.O.R.B.) items are hereby amended and/or clarified under Addendum #4:

Questions

1. Refer to the bid drawings sheet 12; please clarify the telemetry equipment box shown in front view is same as the SS enclosures for electronic actuators shown in side views.

No. The enclosures for the actuators (details on sheet 53) are different than the telemetry equipment box (details on sheet 55).

2. Refer to the bid drawings; please provide the thickness of the riprap layer.

Riprap shall be “Ditch Lining” Material 6” to 12” size and shall be a minimum of 12” thick placed on top of an approved filter fabric.

3. Refer to bid drawings for front and side views of structures; please clarify the handrails will only be provided on the new headwall with gates but not on the modified index end wall?

Handrails are to be provided on the sides and front of each structure that you can walk out onto to operate or services gates. The end walls do not require handrails.

4. Refer to bid drawings; please clarify is the contractor required to backfill with fill material up to the top of the modified index end wall?

The backfill over the culverts is to match the existing bank elevations of the canals. In most cases it will slope from the top of the index wall to the bank elevation.

Acknowledgement of Receipt

Acknowledgement of receipt of this Addendum No. 4 is **required** at the time of receipt, by facsimile of this transmittal faxed to (239) 368-5412 or emailed to MCook@la-msid.com. Failure to acknowledge may result in rejection of Bid. Also, include an original, signed Addendum No. 1 with the Bid Package submitted to the LA-MSID.

I hereby acknowledge the receipt of Addendum No. 4 as identified above.

RECEIVED BY: _____

Print Name

Date: _____